Certificate



No.: 968/V 1031.01/23

Product tested	Pressure Switches	Certificate holder	Ruelco, Inc. 1209 Distributors Row New Orleans, LA 70123 USA			
Type designation	Series SS-4XXX and Model BS					
Codes and standards	IEC 61508 Parts 1-2 and 4-7:2010					
Intended application	Safety Function: The pressure switches change state either of a 3-way valve or of a micro switch, when the set trigger pressure is reached.					
	umented system up to SIL e minimum required e system the switches may					
Specific requirements	The instructions of the associated Installation, Operating and Safety Manual shall be considered. It has to be ensured that the pressure setpoint cannot be changed.					
	For safety applications the idle current principle has to be applied. The redundant contacts of the DPDT micro switch have to be wired in series.					
Summary of test results see	back side of this certificate.					

Valid until 2028-03-14

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V1.0:2017 in its actual version, whose results are documented in Report No. 968/V 1031.01/23 dated 2023-02-09. This certificate is valid only for products, which are identical with the product tested. Issued by the certification body accredited by DAkkS according to DIN EN ISO/IEC 17065. The accreditation is only valid for the scope listed in the annex to the accreditation certificate D-ZE-11052-02-01.

TÜV Rheinland Industrie Service GmbH Bereich Automation Funktionale Sicherheit Wolf P

Köln, 2023-03-14

10/222 12. 12 E A4

TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.

Certification Body Safety & Security for Astonation & Grid

Dipl.-Ing. (FH) Wolf Rückwart





Holder: Ruelco, Inc. 1209 Distributors Row NEW ORLEANS LA 70123 USA

Product tested: Pressure Switches SS - 4xxx and Model BS

Results of Assessment for mechanical devices 4202, 4222(H) and Model BS

Route of Assessment		2 _H / 1 _S		
Type of Sub-system		Туре А		
Mode of Operation		Low Demand Mode		
Hardware Fault Tolerance	HFT	0		
Systematic Capability		SC 3		
Lambda Dangerous confidence level of calculation 1-α = 95 %	λ _D	4.94 E-08 / h	49 FIT	
Lambda Dangerous Undetected assumed Diagnostic Coverage DC = 0 %	λ _{DU}	4.94 E-08 / h	49 FIT	
Average Probability of Failure on Demand 1oo1 assumed Proof Test Interval $T_1 = 730$ h (once every month)	PFD _{avg} (T ₁)	1.80 E-05		
Average Probability of Failure on Demand 1oo2 assumed Proof Test Interval $T_1 = 730$ h (once every month) assumed $\beta_{1002} = 10$ %	PFD _{avg} (T ₁)	1.80 E-06		

Results of Assessment for device with micro switch 4	SPDT		DPDT		
Lambda Dangerous - AC confidence level of calculation 1-α = 95 %	λ_{D_AC}	7.34 E-08 /h	73 FIT	5.18 E-08 /h	52 FIT
Average Probability of Failure on Demand 1oo1 - AC assumed Proof Test Interval $T_1 = 730$ h (once every month)	PFD _{avg_AC} (T ₁)	2.68 E-05		1.89 E-05	
Lambda Dangerous - DC confidence level of calculation 1-α = 95 %	λ_{D_DC}	1.69 E-07 /h	169 FIT	6.14 E-08 /h	61 FIT
Average Probability of Failure on Demand 1oo1 - DC assumed Proof Test Interval $T_1 = 730$ h (once every month)	PFD _{avg_DC} (T ₁)	6.18 E-05		2.24 E-05	

Origin of failure rates

The stated failure rates are the result of the analysis of field feedback data.

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.